



2010

**VILLAGE OF ALBION WATER SYSTEM
ANNUAL WATER QUALITY REPORT
INCLUDING THE TOWNS OF:
ALBION, BARRE, CARLTON, GAINES, MURRAY,
AND
ALBION/ORLEANS CORRECTIONAL FACILITIES**

Annual Drinking Water Quality Report for 2010
Village Of Albion Water System :
35-37 East Bank St. Albion, NY 14411
(Public Water Supply ID# NY 3600596)

Including the Towns of Barre, Carlton, Albion, Gaines, and Murray

Town of Barre WD#1 PWS ID# 360002
Town of Barre WD#2 PWS ID# 3600013
Town of Barre WD#3 PWS ID# 3600019
Town of Barre WD#4 PWS ID# 3600027
Town of Gaines WD#1 PWS ID# 3600597
Town of Gaines WD#2 PWS ID# 3630011
Town of Gaines WD#3 PWS ID# 3630014
Town of Gaines WD#4 PWS ID# 3630018
Town of Gaines WD#5 PWS ID# 3630025
Town of Gaines WD#6 PWS ID# 3630079
Town of Gaines WD#7 PWS ID# 3630091
Town of Gaines WD#8 PWS ID# 3630098
Town of Gaines WD#9 PWS ID# 3630099
Town of Carlton WD PWS ID# 3604569

Town of Albion WD#1 PWS ID# 3623006
Town of Albion WD#2 PWS ID# 3623007
Town of Albion WD#3 PWS ID# 3630001
Town of Albion WD#4 PWS ID# 3630038
Town of Albion WD#5 PWS ID# 3630042
Town of Albion WD#6 PWS ID# 3630079
Town of Albion WD#7 PWS ID# 3630101
Town of Murray WD#3 PWS ID# 3630000
Town of Murray WD#6 PWS ID# 3630012
Town of Murray WD#7 PWS ID# 3630029
Town of Murray WD#8 PWS ID# 3630022
Town of Murray WD#9 PWS ID# 3630039
Town of Murray WD#11 PWS ID# 3630084
Town of Murray WD#13 PWS ID# 3630093

INTRODUCTION

To comply with State regulations, the Village of Albion Water System, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards. Last year we conducted tests for over 120 contaminants. We detected 17 contaminants and found none of those contaminants at a level higher than the State allows. This report provides an overview of last year's quality, included are details about where your water comes from, what it contains, and how it compares to State standards. If you have any questions about this report or concerning your drinking water, please contact Kevin Miller, Chief Operator at 682-3962. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled village board meetings on the 2nd Wednesday of every month. . The meetings are held at the Village Office at 35-37 East Bank Street at 7PM.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source is Lake Ontario which is considered a surface water supply which is located in the Town of Carlton. During 2010, our system did not experience any restriction of our water source. Treatment consists of pre-treatment disinfection, up flow clarification, filtration and post disinfection prior to distribution.

SOURCE WATER ASSESSMENT

The New York State Department of Health completed a Source Water Assessment Report for the Village of Albion Water System as a requirement of the Source Water Assessment Program (SWAP). The Executive Summary of the report states that the Great Lakes watershed is exceptionally large and too big for a detailed evaluation in the SWAP. General drinking water concerns for public water supplies which use these sources include: storm generated turbidity, waste water, toxic sediments, shipping related spills, and problems associated with exotic species (e.g. *Zebra* Mussels-intake clogging and taste and odor problems). The summary below is based on the analysis of the contaminant inventory compiled for the drainage area deemed most likely to impact the drinking water quality of the Village of Albion Water System.

The assessment found a moderate susceptibility to contamination for the source of supply of the Village of Albion Water System. The amount of agricultural lands in the assessment area results in elevated potential for Disinfection By-product precursors, and pesticide contamination. While there are some facilities present, permitted discharges do not likely represent an important threat to source water quality based on their density in the assessment area. There is also noteworthy contamination susceptibility associated with other discrete contaminant sources, and these facilities include: mines.

FACTS AND FIGURES

Our water system serves approximately 15,000 people in the Village of Albion, Albion/Orleans Correctional Facility, and Towns of Albion, Barre, Carlton, Gaines, and Murray. The total water produced in 2010 was 519,016,000 gallons for an average daily production of 1,421,962 gallons a day. The maximum output for a single day was 1,875,000 gallons. The amount of water delivered to customers was 433,586,275 gallons. An additional 12,582,501 gallons were used in the treatment process and Village buildings. This leaves 57,830,052 gallons (16.46%) unaccounted for as a result of leaks, fires, and unmetered Village Buildings. Included in the total water delivered, Village residents used 166,649,004 gallons, the Albion/Orleans Correctional Facility 81,137,000 gallons, the Town of Carlton 55,675,800 gallons, the Town of Gaines 39,943,070 gallons, the Town of Albion 40,197,500 gallons, the Town of Barre 15,246,400 gallons, and the Town of Murray 22,155,000. In 2010, water customers in the Village of Albion were charged \$2.86/1,000 gallons and \$5.00 quarter administration fee for an average yearly charge of \$216.33. The Albion/Orleans Correctional Facility were charged \$3.75/1,000 gallons and \$5.00 quarter administration fee for an average yearly charge of \$158.30. The Town of Carlton charge \$18.00 for the first 3,000 gallons and \$3.90/1,000 gallons after that for an average yearly charge of \$174.62. The Town of Gaines charged \$3.90/1,000 gallons and a \$16.00 quarterly flat fee for an average yearly charge of \$312.45. The Town of Albion charged \$4.25/1,000 gallons and a fee of \$15.00/quarter for an average yearly charge of \$350.05. The Town of Barre charged \$5.00/1,000 gallons for an average yearly charge of \$234.56. The Town of Murray charged \$4.00/1,000 gallons for an average charge of \$196.93. These averages are based on total gallons purchased by the Towns and Correctional Facilities from the Village.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, 19 inorganic compounds, including nitrate, lead and copper, 56 volatile organic compounds, total trihalomethanes, haloacetic acids, 44 synthetic organic compounds, and radiologicals. It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Orleans County Health Department at (585)589-3252.

The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

Table of Detected Contaminants

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
RADIOACTIVE							
Beta Particles	NO	12/6/02	0.973 ± 1.89	pCi/L	N/A	MCL=50 pCi/L	Man Made Emissions
Radium 228	NO	12/6/02	0.237 ± 0.635	pCi/L	0	MCL=15 pCi/L	Erosion of mineral deposits
INORGANICS							
Barium	NO	8/3/10	0.024	mg/L	2.0	MCL= 2.0 mg/L	Erosions of natural deposits runoffs from steel & pulp mill
Chloride	NO	8/3/10	19	mg/L	N/A	MCL= 250 mg/L	Erosion and runoff naturally occurring road salt
Fluoride	NO	Daily	0.7 - 1.2	mg/L	N/A	MCL= 2.2 mg/L	Water treatment additives
Nickel	NO	8/3/10	0.0017	mg/L	N/A	N/A	Erosion of mineral deposits
Sodium	NO	8/5/09	11.0 ⁵	mg/L	N/A	N/A	Naturally occurring road salt
Sulfate	NO	8/3/10	27	mg/L	N/A	MCL= 250 mg/L	Naturally occurring
Lead	NO	9/2/08	ND - 0.047 0.004 ³	mg/L	0	AL= 0.015 mg/L	Corrosion of household plumbing, erosion of natural deposits
Copper	NO	9/2/08	0.006 - 0.46 0.2 ²	mg/L	1.3	AL= 1.3 mg/L	Corrosion of household plumbing, leaching of wood preservatives
Nitrate	NO	8/3/10	0.29	mg/L	10	MCL= 10 mg/L	Runoff from fertilizer septic tank leaching erosion of natural products
DISINFECTION BYPRODUCTS							
Trihalomethanes	NO	Quarterly	20 - 66 38.6 ⁴	ug/L	N/A	MCL= 80 ug/L	Byproduct of drinking water disinfection
Haloacetic Acids	NO	Quarterly	18 - 61 41.1 ⁴	ug/L	N/A	MCL= 60 ug/L	Byproduct of drinking water disinfection
Chlorite	NO	Daily	0.00 - 0.66	mg/L	N/A	MCL= 1.0 mg/L	Byproduct of drinking water disinfection
Chlorine Residual	NO	Daily	0.8 - 1.9	mg/L	N/A	MRDL=4.0 mg/L	Drinking water disinfection
Chlorine Dioxide	NO	Daily	0.02 - 0.41	mg/L	N/A	MCL= 0.8 mg/L	Raw water disinfection
TURBIDITY							
Entry Point ¹	NO	Continuous	0.024-0.133	NTU	N/A	MCL=1.0 NTU TT-95%<0.3 NTU	Soil Runoff

Notes:

1 - Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. Our highest single turbidity measurement (0.133 NTU) for the year occurred on 1/26/10. State regulations require that turbidity must always be below 1 NTU. The regulations require that 95% of the turbidity samples collected have measurements below 0.3 NTU. The levels recorded were within the acceptable range allowed and did not constitute a treatment technique violation.

2 - The level presented represents the 90th percentile of the 30 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case 30 samples were collected at your water system and the 90th percentile value was 0.2 mg/L. The action level for copper was not exceeded at any of the sites tested.

3 - The level presented represents the 90th percentile of the 30 samples collected. The 90th percentile value for lead was 0.004 mg/L, which is acceptable. The action level for lead was exceeded at two of the 30 sites tested.

4 - This level represents the annual quarterly average calculated from data collected.

5- Water containing >20mg/L Sodium should not be used for drinking water by people on severely restricted Sodium diets. Water containing < 270mg/L sodium should not be used for drinking water by people on a moderately restricted sodium diet.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/L): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/L): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/L): Corresponds to one part of liquid in one trillion parts of liquid (parts per trillion - ppt).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Million Fibers per Liter (MFL): A measure of the presence of asbestos fibers that is longer than 10 micrometers.

The following contaminants were tested for but not detected: Asbestos, Aldicarb, AldicarbSulfone, AldicarbSulfoxide, Carbaryl, Carbofuran, 3-Hydroxycarbofuran, Methomyl, Hexachlorocyclopentadiene, Toxaphene, Oxamyl, Alachlor, Aldrin, Atrazine, Benzo(s)pyrene, Lindane, Butachlor, alpha-chlordane, gamma-chlordane, Dieldrin, Endrin, bis(2-ethylhexyl)adipate, bis(2ethylhexyl)phthalate, Heptachlor, Heptachlorepoxyde, Hexachlorobenzene, Methoxychlor, Metolachlor, Metribuzin, Propachlor, Simazine, 2,4,D, Dalipon, Dinoseb, Pentachlorophenol, Picloram, 2,4,5-TPSilvex, Benzene, Bromobenzene, Bromodichloromethane, sec-butylbenzene, n-butylbenzene, tert-Butylbenzene, Carbontetrachloride, Chlorobenzene, Chloroethane, Chloromethane, 2-Chlorotoluene, 4-Chlororoluene, Dibromomethane, 1,2Dichloroethane, 1,3Dichlorobenzene, 1,4Dichlorobenzene, Dichlorofluoromethane, 1,1 Dichloroethane, 1,2Dichloroethane, cis 1,1 Dichloroethene, 1,1 Dichloroethane, trans 1,2Dichloroethane, 1,2Dichloropropane, 1,3Dichloropropane, 2,2Dichloropropane, 1,1 Dichloropropene, cis 1,3 Dichloropropene, trans 1,3Dichloropropene, Ethylbenzene, Hexachlorobutadiene, Cuymene, Cymene, Methylenechloride, N-Propylbenzene, Styrene, 1,1,1,2Tetrachloroethane, 1,1,2,2Tetrachloroethane, Tetrachloroethene, Freon 1,1,2,3Trichloropropane, 1,2,4Trimethylbenzene, 1,3,5Trimethylbenzene, Vinylchloride, m-xylene, p-xylene, 1,2-Dibromo-3chloropropane, MTBE, Antimony, Arsenic, Beryllium, Cadmium, Mercury, Selenium, Thallium, Manganese, Silver, Zinc, Cyanide.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State. It should be noted that the action level for lead was exceeded at two of the 30 sites sampled. We are required to present the following information on lead in drinking water:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your homes plumbing. The Village of Albion is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

INFORMATION ON FLUORIDE ADDITION

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. Fluoride is added to your water by the Village of Albion Water Treatment Plant before it is delivered to you. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at an optimal range from 0.7 to 1.2 mg/1 (parts per million). To ensure that the fluoride supplement in your water provides optimal dental protection, the State Department of Health requires that the Village of Albion Water Treatment Plant monitor fluoride levels on a daily basis. During 2010 monitoring showed fluoride levels in your water were in the optimal range 100 % of the time.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2010, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

INFORMATION FOR NON-ENGLISH SPEAKING RESIDENTS

Spanish Este informe contiene informacion muy importante sobre su agua beber. Traduzcalo o hable con alguien que lo entienda bien.

French Ce rapport contient des informations importantes sur votre eau potable. Traduisez-le ou parlez en avec quelqu'un qui le comprend bien.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- * Saving water saves energy and some of the costs associated with both of these necessities of life.
- * Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- * Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less. It is not hard to conserve water. Conservation tips include:

- * Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- * Turn off the tap when brushing your teeth.
- * Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- * Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, and then check the meter after 15 minutes. If it moved, you have a leak

SYSTEM IMPROVEMENTS

The treatment process at the Village of Albion is steadily improving. Also a security system has been purchased and will be installed soon at the treatment facility.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. It is our commitment as New York State Licensed Water Treatment Plant Operators to provide you with the best water quality possible at your tap and we feel this report confirms that we have met that commitment. A copy of this report will be available at the Village Office, Swan Library, each of the Town Halls, and for those that have internet access: <http://www.vil.albion.ny.us>. If you have any questions feel free to call:

Water Quality or to report a leak - Village of Albion WTP 682-3962

Customer Service: Village of Albion 589-9176, Town of Carlton- 682-4358 (Dave Krull, Hwy. Supt.)

Town of Gaines- 589-5833 (Ron Manella, Hwy Supt.), Town of Albion- 589-7048 (Jed Standish, Hwy. Supt.)

Town of Barre- 589-5100 (Dale Ostroski, Hwy. Supt.), Town of Murray- 638-8507 (Ed Morgan, Hwy. Supt.)